

 		Anlage: TBG 924-2K ARA Lachen				Betriebs.-h: 889	Datum: 04.01.18			
						Aufstellhöhe: 408				
Zeit	Gaszähler	Gas Temp.	Gas Druck	Luftdruck	el. Energie	Messwerte	Nr. 100%	Nr. 80%	Nr. 60%	
11:20	0	75417,6	23,0	22,0	959	0	Luftfeuchtigkeit	52/52	52/52	52/53
	15	75432,7				28,60	Leistung el.	115/115	53/55	70/70
100%	30	75447,8	24,4			57,23	Receiver Temp.	63,6/63,7	64,4/63,9	65,3/65,7
	45	75463,0				85,85	Br. Raumtemp. Ø	500/490	480/	480/
	60	75478,15	24,5	22,0		114,5	Temp. v. Turbo	598/597	582/582	564/563
							Temp. n. Kat.	538/536	547/547	549/557
12:42	0	75498,3	24,5	21,2	958	0	Lambdawert Ø	0,992/0,992	0,985/0,984	0,982/0,984
	15	75511,0	24,2	21,4		23,25	Zündzeitpunkt	32,5/32,5	32/32,5	32,5
80%	30	75523,65		21,2		46,50	Drosselklappe	64,0/64,3	52,4/52,7	44,4/44,7
	45	75536,3	24,1			69,75	KW-Temp. Austritt	86,5/86,0	86,0/86,0	86,0/86,1
	60	75548,95				92,98	GK-Kreis Eintritt	77,6/78,0	78,5/79,1	79,6/79,5
							GK-Kreis Austritt	52,7/51,8	55,8/55,7	60,0/60,2
13:58	0	75560,4	23,6	20,6	958	0	Verbr.-lufttemp.	20,9/20,5	21,9/22,1	23,9/24,0
	15	75570,4	23,4			17,54	Abgasgegendruck			
60%	30	75580,3	23,2			34,86	Abgas By-pass			
	45	75590,3	23,1			52,47	Gemisch By-pass			
	60	75600,2				69,99				
		A _{1,2,3}	V ₁	V ₂	V ₃					
HB	100%	1,6/2,9/3,0	239	239,5	239					
	80%	1,5/2,8/2,9	239,5	239	238,7					
	60%	1,5/2,8/2,3	238	239	238,5					