

Datum	CSB tot. / BSB5	Verhältnis		Zulauf Rohabwasser Auslastung ARA								Auslastung ARA hydraulisch	
		P tot. / BSB5	NH4-N / BSB5	CSB tot.		BSB5		P tot.		N ges.		Q TW	Q RW
				%	EW	%	EW	%	EW	%	EW	%	%
1997 Anz	51	15	47	52	52	51	51	135	135	0	0	365	365
Minimum	1.31	0.03	0.08	30.9	10494	34.4	11687	21.9	7433			32.8	16.4
Mittelwert	1.83	0.04	0.15	49.8	16921	54.7	18615	56.6	19257			88.8	44.4
Maximum	2.17	0.05	0.26	72.4	24614	87.9	29892	109.1	37088			215.3	107.6
Summe / Total													
1998 Anz	50	3	50	50	50	50	50	103	103	0	0	365	365
Minimum	1.48	0.03	0.07	29.6	10049	31.9	10857	30.2	10264			47.6	23.8
Mittelwert	1.86	0.03	0.18	41.8	14226	45.1	15342	49.4	16794			98.6	49.3
Maximum	2.16	0.04	0.31	58.9	20010	63.8	21683	77.6	26391			238.9	119.5
Summe / Total													
1999 Anz	51	2	44	52	52	51	51	99	99	0	0	365	365
Minimum	1.46	0.02	0.07	38.2	12986	40.1	13634	34.0	11563			33.4	16.7
Mittelwert	2.07	0.02	0.12	71.3	24245	70.4	23933	59.4	20198			118.3	59.2
Maximum	2.66	0.03	0.23	102.1	34706	111.3	37835	118.7	40350			263.6	131.8
Summe / Total													
2000 Anz	53	1	53	53	53	53	53	103	103	0	0	366	366
Minimum	1.80	0.03	0.06	52.4	17828	36.5	12396	36.5	12410			57.7	28.8
Mittelwert	2.25	0.03	0.12	80.9	27521	73.3	24925	64.1	21786			106.3	53.2
Maximum	3.31	0.03	0.19	142.4	48399	132.4	45032	113.8	38703			224.9	112.4
Summe / Total													
2001 Anz	55	1	53	55	55	55	55	102	102	0	0	365	365
Minimum	1.54	0.03	0.08	35.8	12188	42.5	14459	32.9	11193			48.7	24.3
Mittelwert	2.31	0.03	0.13	76.2	25915	65.8	22372	64.4	21902			108.1	54.0
Maximum	2.61	0.03	0.37	130.0	44187	106.0	36053	120.9	41116			225.4	112.7
Summe / Total													
Anzahl	260	22	247	262	262	260	260	542	542	0	0	1826	1826
Minimum	1.31	0.02	0.06	29.6	10049	31.9	10857	21.9	7433			32.8	16.4
Mittelwert	2.07	0.03	0.14	64.4	21893	62.1	21110	58.6	19939			104.0	52.0
Maximum	3.31	0.05	0.37	142.4	48399	132.4	45032	120.9	41116			263.6	131.8
Summe / Total													