

Datum	CSB tot. / BSB5	Verhältnis		Zulauf Rohabwasser Auslastung ARA								Auslastung ARA hydraulisch	
		P tot. / BSB5	NH4-N / BSB5	CSB tot.		BSB5		P tot.		N ges.		Q TW	Q RW
				%	EW	%	EW	%	EW	%	EW	%	%
<b>2002</b> Anz	53	4	52	54	54	56	56	104	104	0	0	365	365
Minimum	1.48	0.02	0.07	47.1	16005	32.3	10983	32.9	11179			50.5	25.3
Mittelwert	2.39	0.03	0.14	67.5	22941	58.9	20031	63.1	21439			105.4	52.7
Maximum	3.22	0.04	0.24	106.3	36146	110.9	37707	105.4	35843			222.2	111.1
<b>Summe / Total</b>													
<b>2003</b> Anz	73	12	74	81	81	87	87	100	100	0	0	365	365
Minimum	1.10	0.01	0.03	42.2	14355	10.7	3642	36.7	12489			51.4	25.7
Mittelwert	1.93	0.02	0.12	73.5	25004	84.4	28700	70.6	24001			87.7	43.8
Maximum	11.58	0.03	1.40	142.8	48559	165.6	56303	126.8	43121			250.6	125.3
<b>Summe / Total</b>													
<b>2004</b> Anz	94	87	99	97	97	109	109	209	209	0	0	366	366
Minimum	1.10	0.02	0.01	43.2	14698	37.8	12860	30.1	10224			46.7	23.4
Mittelwert	1.66	0.02	0.12	72.4	24621	89.8	30520	70.7	24048			97.6	48.8
Maximum	2.99	0.05	0.43	151.4	51468	207.3	70467	138.0	46907			263.7	131.9
<b>Summe / Total</b>													
<b>2005</b> Anz	81	26	81	88	88	88	88	107	107	0	0	365	365
Minimum	0.59	0.01	0.01	44.1	14988	42.9	14583	45.1	15331			49.4	24.7
Mittelwert	1.59	0.02	0.12	69.2	23539	89.9	30552	73.1	24851			100.3	50.2
Maximum	3.46	0.05	0.34	111.1	37765	164.2	55830	187.2	63659			261.4	130.7
<b>Summe / Total</b>													
<b>2006</b> Anz	95	34	88	101	101	96	96	111	111	0	0	365	365
Minimum	1.05	0.02	0.07	27.3	9287	18.5	6300	38.6	13124			47.4	23.7
Mittelwert	1.92	0.03	0.17	61.8	21011	68.1	23162	65.0	22104			98.2	49.1
Maximum	7.82	0.05	1.20	98.7	33558	142.0	48293	100.8	34277			240.4	120.2
<b>Summe / Total</b>													
<b>Anzahl</b>	396	163	394	421	421	436	436	631	631	0	0	1826	1826
Minimum	0.59	0.01	0.01	27.3	9287	10.7	3642	30.1	10224			46.7	23.4
Mittelwert	1.85	0.02	0.14	68.8	23387	80.0	27196	68.8	23405			97.9	48.9
Maximum	11.58	0.05	1.40	151.4	51468	207.3	70467	187.2	63659			263.7	131.9
<b>Summe / Total</b>													