

Datum	CSB tot. / BSB5	Verhältnis		Zulauf Rohabwasser Auslastung ARA								Auslastung ARA hydraulisch	
		P tot. / BSB5	NH4-N / BSB5	CSB tot.		BSB5		P tot.		N ges.		Q TW	Q RW
				%	EW	%	EW	%	EW	%	EW	%	%
2007 Anz	90	26	87	106	106	90	90	111	111	0	0	365	365
Minimum	1.07	0.02	0.05	36.8	12518	29.6	10060	31.0	10533			60.0	30.0
Mittelwert	1.90	0.03	0.12	73.9	25125	82.0	27865	72.6	24696			98.9	49.4
Maximum	4.52	0.06	0.35	119.9	40750	139.3	47363	125.1	42525			210.5	105.2
Summe / Total													
2008 Anz	135	62	134	138	138	140	140	149	149	0	0	366	366
Minimum	1.00	0.02	0.05	37.3	12671	37.8	12841	40.1	13644			63.1	31.5
Mittelwert	1.80	0.03	0.13	73.3	24929	82.1	27921	73.2	24903			103.7	51.8
Maximum	3.55	0.05	0.36	126.9	43143	188.7	64150	140.6	47793			211.1	105.6
Summe / Total													
2009 Anz	133	47	130	138	138	138	138	148	148	0	0	365	365
Minimum	1.27	0.02	0.06	43.5	14793	31.3	10654	52.3	17792			58.0	29.0
Mittelwert	1.85	0.03	0.13	76.4	25970	84.3	28674	76.3	25953			101.4	50.7
Maximum	4.37	0.04	0.54	122.7	41708	147.3	50085	108.1	36742			204.4	102.2
Summe / Total													
2010 Anz	123	27	123	130	130	129	129	137	137	0	0	365	365
Minimum	1.00	0.02	0.05	47.5	16164	26.1	8860	41.0	13926			60.8	30.4
Mittelwert	1.87	0.03	0.14	75.5	25655	83.6	28408	78.5	26674			114.9	57.5
Maximum	5.50	0.05	0.39	149.8	50928	213.8	72680	123.9	42142			250.5	125.3
Summe / Total													
2011 Anz	118	24	116	125	125	124	124	130	130	0	0	365	365
Minimum	0.96	0.02	0.06	38.8	13196	31.7	10772	27.6	9393			60.2	30.1
Mittelwert	1.89	0.03	0.13	75.6	25699	82.6	28092	72.6	24690			96.1	48.1
Maximum	4.45	0.03	0.27	130.5	44367	181.8	61823	101.7	34567			199.1	99.6
Summe / Total													
Anzahl	599	186	590	637	637	621	621	675	675	0	0	1826	1826
Minimum	0.96	0.02	0.05	36.8	12518	26.1	8860	27.6	9393			58.0	29.0
Mittelwert	1.86	0.03	0.13	75.0	25487	83.0	28216	74.8	25417			103.0	51.5
Maximum	5.50	0.06	0.54	149.8	50928	213.8	72680	140.6	47793			250.5	125.3
Summe / Total													