

Datum	Verhältnis			Zulauf Rohabwasser Auslastung ARA								Auslastung ARA hydraulisch	
	CSB tot. / BSB5	P tot. / BSB5	NH4-N / BSB5	CSB tot.		BSB5		P tot.		N ges.		Q TW %	Q RW %
				%	EW	%	EW	%	EW	%	EW		
2017 Anz	74	73	73	78	78	75	75	78	78	0	0	365	365
Minimum	1.25	0.01	0.07	58.4	19'852	58.2	19'773	36.2	12'293			66.6	33.3
Mittelwert	1.85	0.02	0.12	92.8	31'563	100.6	34'210	70.8	24'070			120.3	60.2
Maximum	2.81	0.03	0.20	156.6	53'253	171.7	58'392	135.8	46'186			254.0	127.0
Summe/Total													
2018 Anz	21	21	21	60	60	21	21	61	61	25	25	365	365
Minimum	1.52	0.02	0.10	53.0	18'032	81.8	27'807	48.0	16'315	40.0	13'604	50.1	25.0
Mittelwert	1.85	0.02	0.13	91.6	31'142	110.2	37'455	71.0	24'127	66.3	22'557	101.8	50.9
Maximum	2.29	0.03	0.25	143.7	48'864	150.1	51'033	103.6	35'230	91.7	31'169	221.3	110.7
Summe/Total													
2019 Anz	3	3	3	77	77	4	4	79	79	77	77	365	365
Minimum	1.81	0.02	0.10	55.2	18'755	95.5	32'465	55.4	18'833	49.9	16'950	70.2	35.1
Mittelwert	1.87	0.02	0.13	103.8	35'292	100.7	34'241	87.2	29'633	82.0	27'894	130.5	65.3
Maximum	1.90	0.02	0.17	203.8	69'297	113.0	38'413	163.3	55'509	196.6	66'843	301.8	150.9
Summe/Total													
Anzahl	98	97	97	215	215	100	100	218	218	102	102	1'095	1'095
Minimum	1.25	0.01	0.07	53.0	18'032	58.2	19'773	36.2	12'293	40.0	13'604	50.1	25.0
Mittelwert	1.85	0.02	0.12	96.4	32'781	102.6	34'893	76.8	26'102	78.2	26'586	117.6	58.8
Maximum	2.81	0.03	0.25	203.8	69'297	171.7	58'392	163.3	55'509	196.6	66'843	301.8	150.9
Summe/Total													