

Von 01.01.2017

Bis 31.12.2019

Datum	Absetz- volumen AV ml/l	Trocken- substanz TS g/l	Zulauf TS Online		Zulauf TS Online			Schlamm- vol. index SVI mg/l	Glüh- rückstand GR %	Glüh- verlust GV %	O2-Online			Temperatur Online		
			Kontroll- messung g/l	Ab- weichung %	min. g/l	mit. g/l	max. g/l				min. mg/l	mit. mg/l	max. mg/l	min. °C	mit. °C	max. °C
2017	Anz	247	247	365	247	365	365	247	0	0	365	365	365	365	365	365
Minimum		140	2.1	1.4	80.3	0.0	2.2	2.5	56.1		0.0	0.4	2.9	0.0	6.8	8.2
Mittelwert		318	3.1	2.9	106.7	1.4	3.0	3.5	103.8		0.4	2.6	7.2	14.6	15.3	15.8
Maximum		490	4.2	3.8	255.7	3.2	3.9	13.4	174.4		1.8	6.0	12.6	21.4	21.8	33.4
Summe/Total																
2018	Anz	242	242	365	242	365	365	242	0	0	365	365	365	365	365	365
Minimum		150	1.9	2.3	68.2	0.6	2.3	2.5	58.3		0.0	0.4	2.8	1.7	7.8	8.5
Mittelwert		269	3.0	2.9	102.0	1.6	3.0	3.4	89.0		0.2	2.2	6.2	15.6	16.1	16.5
Maximum		450	4.1	3.8	125.0	3.3	3.9	14.9	122.1		1.7	5.2	12.6	22.6	22.9	23.2
Summe/Total																
2019	Anz	242	242	365	242	365	365	242	0	0	365	365	365	365	365	365
Minimum		140	1.9	1.7	56.8	0.0	2.0	2.3	56.8		0.0	0.9	3.2	6.0	7.8	8.9
Mittelwert		253	3.0	3.0	101.5	1.6	3.1	3.5	83.5		0.1	2.1	5.3	14.8	15.4	15.8
Maximum		390	4.0	3.7	132.9	2.9	3.8	13.2	117.2		1.5	3.5	12.4	21.5	21.7	25.1
Summe/Total																
Anzahl		731	731	1'095	731	1'095	1'095	1'095	731	0	0	1'095	1'095	1'095	1'095	1'095
Minimum		140	1.9	1.4	56.8	0.0	2.0	2.3	56.1		0.0	0.4	2.8	0.0	6.8	8.2
Mittelwert		280	3.0	2.9	103.4	1.5	3.1	3.5	92.2		0.3	2.3	6.2	15.0	15.6	16.1
Maximum		490	4.2	3.8	255.7	3.3	3.9	14.9	174.4		1.8	6.0	12.6	22.6	22.9	33.4
Summe/Total																