

Datum	Zulauf ARA - Ablauf ARA				
	CSB tot. %	BSB5 %	P tot. %	N ges. %	NH4-N %
<b>2007</b> Anz	106	90	110	0	105
Minimum	83.1	82.5	76.3		10.6
Mittelwert	93.2	97.8	95.5		67.0
Maximum	97.4	99.7	98.4		99.9
<b>Summe / Total</b>					
<b>2008</b> Anz	138	136	149	0	134
Minimum	85.1	92.0	82.6		52.3
Mittelwert	93.7	98.4	93.6		93.9
Maximum	97.1	99.7	98.4		99.9
<b>Summe / Total</b>					
<b>2009</b> Anz	138	136	148	0	139
Minimum	86.1	90.0	86.2		29.2
Mittelwert	93.8	98.4	94.9		88.5
Maximum	97.1	99.7	98.4		99.9
<b>Summe / Total</b>					
<b>2010</b> Anz	130	129	136	0	128
Minimum	85.3	93.3	86.5		19.5
Mittelwert	93.6	98.4	94.9		83.4
Maximum	97.2	99.7	98.3		99.9
<b>Summe / Total</b>					
<b>2011</b> Anz	125	124	130	0	121
Minimum	85.0	92.5	80.9		39.3
Mittelwert	95.1	98.3	94.5		87.8
Maximum	98.1	99.7	98.6		99.9
<b>Summe / Total</b>					
<b>Anzahl</b>	637	615	673	0	627
Minimum	83.1	82.5	76.3		10.6
Mittelwert	93.9	98.3	94.6		84.9
Maximum	98.1	99.7	98.6		99.9
<b>Summe / Total</b>					