

Datum	Faulraum								Faulraum Auslauf				Trüb- wasser Menge m³
	Trocken- rückstand %	Glüh- rückstand %	Glüh- verlust %	Abbau- leistung %	Temp. vor WT °C	pH-Wert pH	Organ. Säure mg/l	Faulzeit d	Trocken- rückstand %	Glüh- rückstand %	Glüh- verlust %	pH-Wert %	
1991 Anz	49	49	49	49	365	49	0	363	49	49	49	49	0
Minimum	2.5	50.5	42.7	43.0	37.0	7.0		16.7	4.1	51.3	41.1	7.0	
Mittelwert	2.9	52.7	47.3	57.1	39.3	7.2		20.7	6.4	55.4	44.6	7.1	
Maximum	3.4	57.3	49.5	76.7	42.0	7.4		33.3	9.5	58.9	48.7	7.3	
Summe / Total													
1992 Anz	37	37	37	37	366	37	0	366	37	37	37	37	0
Minimum	2.8	50.2	46.3	46.8	30.0	6.1		14.1	3.7	53.0	42.0	7.0	
Mittelwert	3.9	51.8	48.2	58.6	36.8	6.4		22.6	6.3	55.1	44.9	7.2	
Maximum	5.0	53.7	49.8	71.9	42.0	7.4		29.4	7.9	58.0	47.0	7.4	
Summe / Total													
1993 Anz	43	43	43	43	365	43	0	364	43	43	43	43	0
Minimum	2.9	48.0	47.6	46.7	30.0	5.9		15.9	2.5	49.0	42.9	7.0	
Mittelwert	3.5	50.6	49.4	57.5	35.5	6.3		20.3	4.7	53.0	47.0	7.3	
Maximum	4.1	52.4	52.0	70.8	39.0	6.7		29.4	6.6	57.1	51.0	7.5	
Summe / Total													
1994 Anz	51	51	51	51	365	51	0	365	51	51	51	51	0
Minimum	2.3	47.3	46.8	43.2	35.0	5.7		15.4	2.8	49.0	44.5	6.8	
Mittelwert	3.5	50.0	50.0	54.1	38.5	6.1		19.7	4.6	51.7	48.3	7.0	
Maximum	4.9	53.2	52.7	68.4	44.0	6.5		28.6	6.4	55.5	51.0	7.4	
Summe / Total													
1995 Anz	40	40	40	40	365	40	0	364	42	42	42	42	0
Minimum	2.7	48.1	43.8	46.1	31.0	5.8		17.5	3.6	49.5	30.0	6.6	
Mittelwert	4.0	51.4	48.6	58.1	37.8	6.1		25.4	6.8	55.5	44.5	6.9	
Maximum	6.5	56.2	51.9	75.2	41.0	6.6		45.5	13.9	70.0	50.5	7.2	
Summe / Total													
1996 Anz	24	24	24	24	366	24	0	365	47	47	47	47	0
Minimum	3.5	45.6	50.2	39.2	30.0	5.6		22.2	2.7	46.7	48.7	7.0	
Mittelwert	4.5	47.9	52.1	55.9	34.4	6.3		25.9	3.9	49.1	50.9	7.4	
Maximum	5.5	49.8	54.4	64.7	40.0	6.9		33.3	5.1	51.3	53.3	7.6	
Summe / Total													
Anzahl	244	244	244	244	2192	244	0	2187	269	269	269	269	0
Minimum	2.3	45.6	42.7	39.2	30.0	5.6		14.1	2.5	46.7	30.0	6.6	
Mittelwert	3.6	50.9	49.1	56.8	37.1	6.4		22.4	5.4	53.2	46.8	7.2	
Maximum	6.5	57.3	54.4	76.7	44.0	7.4		45.5	13.9	70.0	53.3	7.6	
Summe / Total													