

Datum	Faulraum								Faulraum Auslauf				Trüb- wasser Menge m³
	Trocken- rückstand %	Glüh- rückstand %	Glüh- verlust %	Abbau- leistung %	Temp. vor WT °C	pH-Wert pH	Organ. Säure mg/l	Faulzeit d	Trocken- rückstand %	Glüh- rückstand %	Glüh- verlust %	pH-Wert %	
<b>1997</b> Anz	41	41	41	41	365	41	0	365	52	52	52	52	0
Minimum	3.2	46.0	45.5	47.2	32.0	5.9		20.0	3.0	45.2	43.5	7.0	
Mittelwert	4.6	49.2	50.8	62.9	32.6	6.2		23.7	4.1	49.5	50.5	7.4	
Maximum	5.4	54.5	54.0	77.5	33.0	6.5		28.6	5.5	56.5	54.8	7.6	
<b>Summe / Total</b>													
<b>1998</b> Anz	51	51	51	51	365	51	0	363	51	51	51	51	0
Minimum	3.5	46.9	43.1	42.7	3.2	5.9		22.2	2.8	47.9	43.0	6.9	
Mittelwert	4.5	50.5	49.5	60.3	32.0	6.3		26.6	5.3	52.8	47.2	7.3	
Maximum	6.0	56.9	53.1	73.2	35.0	7.3		33.3	8.1	57.0	52.1	8.0	
<b>Summe / Total</b>													
<b>1999</b> Anz	50	50	50	50	361	50	0	364	50	50	50	48	0
Minimum	3.3	48.9	45.5	45.9	32.0	6.0		18.2	3.1	51.0	41.3	6.7	
Mittelwert	4.6	51.5	48.5	60.8	32.7	6.5		28.5	6.6	54.9	45.1	7.3	
Maximum	6.6	54.5	51.1	76.8	35.0	7.0		50.0	8.8	58.7	49.0	7.6	
<b>Summe / Total</b>													
<b>2000</b> Anz	52	52	52	52	366	52	0	365	52	52	52	52	0
Minimum	3.8	46.8	44.9	37.5	32.0	5.8		20.0	2.6	49.9	40.1	6.5	
Mittelwert	4.7	50.4	49.6	59.0	32.7	6.2		25.4	6.8	54.0	46.0	7.1	
Maximum	6.1	55.1	53.3	72.5	33.0	6.6		28.6	9.6	59.9	50.1	7.4	
<b>Summe / Total</b>													
<b>2001</b> Anz	49	49	49	49	365	49	0	365	49	49	49	49	0
Minimum	3.6	48.1	47.2	50.9	32.0	6.0		18.2	3.1	49.1	44.8	6.9	
Mittelwert	4.6	50.0	50.0	61.5	33.0	6.3		25.1	6.0	51.8	48.2	7.2	
Maximum	5.5	52.8	51.9	72.8	34.0	6.6		28.6	7.9	55.2	50.9	7.5	
<b>Summe / Total</b>													
<b>Anzahl</b>	243	243	243	243	1822	243	0	1822	254	254	254	252	0
Minimum	3.2	46.0	43.1	37.5	3.2	5.8		18.2	2.6	45.2	40.1	6.5	
Mittelwert	4.6	50.4	49.6	60.8	32.6	6.3		25.9	5.8	52.6	47.4	7.3	
Maximum	6.6	56.9	54.0	77.5	35.0	7.3		50.0	9.6	59.9	54.8	8.0	
<b>Summe / Total</b>													